



**NOTES:**

EACH IP-7ST HAS A SWITCH ADJACENT TO THE DIN RAIL BRACKET, THIS MUST BE SWITCHED TOWARDS THE BRACKET.

CUT LK1 ON AMP-LE TO SEPARATE THE E & -VE TERMINALS.

IMAGES USED ARE FOR REPRESENTATION ONLY AND MAY NOT SHOW ACTUAL PRODUCTS USED.

 <p>BC TECHNOLOGY LTD BCTEC HOUSE WALLIS CLOSE PARK FARM IND EST WELLINGBOROUGH NN8 6AG TEL: 01933 405050 FAX: 01933 405454</p>	<b>TITLE:</b>  IP7-ST Wiring Diagram		<b>CUSTOMER REF:</b> Single Door IP7-ST Drawing		<b>DRAWING REF:</b> IP7-ST Drawing	
	<b>DATE:</b> 06/03/09	<b>CABLE TYPE:</b> Multi-core Alarm Cable		<b>MAXIMUM DISTANCE:</b> 150M Using Alarm Cable		<b>PG:</b> 1 OF 1
	<b>DRAWN BY:</b> Sales Support		<b>DESCRIPTION:</b> Connection diagram showing an AMP-LE-S connected to a single IP7-ST.			